

## DTS 2021 Evacuation Drills

An unannounced evacuation drill for the **Dallas campus** was held on December 16, 2021 between 8:30am and 10:10am. The alarms were sounded in one building at a time and occupants were required to evacuate the buildings. Most of the alarm systems worked as designed. We found that the alarm system for the Mitchell/Book Store buildings had been silenced and the horn strobes were disabled and it was reset. We talked about reminding everyone where their muster points are and staying at least 50 feet away from the buildings. A successful test of the DTS alert system was conducted on 01/12/2022.

---

### Houston Campus

Property: Property Manager:

Frequency:

Date:

#### Area Operations

##### Item Fire Drill ListID : 112

7100 Regency Square Boulevard Ali Bana Annual

12/15/2021

#### Fire Drill Records: Response Notes

Notification method used Email and Posted Notices. Unannounced to Houston campus.

Staff members on duty and participating Yes

Number of Occupants evacuated 40 - 60

Were there any issues during the Fire Drill? Yes

Weather conditions when occupants were evacuated Clear

Time required to accomplish complete evacuation Less than 10 minutes

Was local fire department notified? No

Was a Fire Marshal present No

Staff is certified in fire safety procedures as required by local codes

and a copy of the certifications are filed in the Employee

Certification/License Entities {currently this is only a requirement for

Houston high - rise and mid - rise atrium buildings}

Yes

#### Other

##### Comments

**Created By** Ali Bana

12/16/2021 11:55:38 AM

**Modified By**

---

The annual fire/evacuation drill for the **DTS-Washington DC** campus was completed on October 23, 2021 during classes at Burke Community Church, 9900 Old Keene Mill Road, Burke, Virginia 22015. We evacuated two classrooms of students, faculty and staff for a total of 12 people. Staff members checked the bathrooms and we all met in the far parking lot in 2min 30sec. We received excellent cooperation for this exercise from students and faculty. The drill was unannounced.

---

On Friday, December 3, 2021 the **Atlanta Extension** of Dallas Theological Seminary at North Point Community Church conducted an announced emergency evacuation drill. Jake Gross, Dean of DTS-Atlanta, conducted the drill. The following was identified:

- Smoke detectors and fire suppression sprinkler systems were observed in the classroom space and throughout the facility.
- Egress from the classroom space to building exterior took less than 35 seconds upon sounding the alarm. Egress was conducted walking at a normal, unhurried, pace.
- A safe gathering spot for evacuees to gather outside the building was identified. The location is the second tier of the parking lot, directly out the egress door of the building.

On Wednesday, December 15, 2021 the Atlanta Extension of Dallas Theological Seminary at Passion City Church conducted an announced emergency evacuation drill. Jake Gross, Dean of DTS-Atlanta, conducted the drill. The following was identified:

- Smoke detectors and fire suppression sprinkler systems were observed in the classroom space and throughout the facility.
- Egress from the classroom space to building exterior took 41 seconds upon sounding the alarm. Egress was conducted walking at a normal, unhurried, pace.
- A safe gathering spot for evacuees to gather outside the building was identified. The location is the parking lot, directly outside the egress door of the building.